	TION TO DIE	TO A PERON OF CONTRACT		1. CONTRACT ID CODE	PAGE OF PAGES	
AMENDMENT OF SOLICITA	TION/MODIF	ICATION OF CONTRACT		J	1 2	
2. AMENDMENT/MODIFICATION NO.	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQ. NO.		5.РКОЛ	ECT NO.(If applicable)	
0005	09-Apr-2011	MIPROHRF2N0041		11-C006		
6. ISSUED BY CODE	W5J9JE	7. ADMINISTERED BY (Ifother than item 6)		CODE		
AFGHANISTAN DISTRICT NORTH (AEN) US ARMY CORPS OF ENGINEERS OPERATION ENDURING FREEDOM APO AE 09356		See Item 6				
8. NAME AND ADDRESS OF CONTRACTOR (State and Zip Code)	X 9A. AMENDMENT OF SOLICITATION NO. W5J9JE-11-R-0067				
			Х	9B. DATED (SEE ITEM 11) 22-Feb-2011		
				10A. MOD. OF CONTRACT/ORDER NO.		
CODE FACILITY CODE				10B. DATED (SEE ITEM 13)		
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS						
The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer				is extended, χ is not	extended.	
(a) By completing Items 8 and 15, and returningcopies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegramwhich includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegramor letter, provided each telegramor letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified. 12. ACCOUNTING AND APPROPRIATION DATA (If required)						
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.						
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.						
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B). C. THIS SUPPLEMENT AL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:						
C. THIS SUFFLEMENT AL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF.						
D. OTHER (Specify type of modification and authority)						
E. IMPORTANT: Contractor is not, is required to sign this document and return copies to the issuing office.						
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)						
Project Description: ANA PeC Garrison Growth Units and Electrical Upgrade (PeC#6), Kabul, Afghanistan						
The purpose of this amendment is to provide responses to RFIs. ***********************************						
Except as provided herein, all terms and conditions of the document referenced in Item9A or 10A, as heretofore changed, remains unchanged and in full force and effect.						
15A. NAME AND TITLE OF SIGNER (Type or	16A. NAME AND TITLE OF CO	_		pe or print)		
		TEL:		EMAIL:		
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNEI	16B. UNITED STATES OF AMER	RIC.	A	16C. DATE SIGNED	
		BY			09-Apr-2011	
(Signature of person authorized to sign)		(Signature of Contracting Of	fice	r)		

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text: AMENDMENT 0005

- a. The proposal due date remain the same. Proposal due date is 3:00 pm local time, Sunday, April 10, 2011.
- b. The following are responses to Request for Information (RFI's) submitted.
 - 47. Referring to Amd #4 Q&A q. 45, indicates that interior telecommunication shall follow the "for information drawings", although there is a conflict between technical requirements section 01015 Para 4.7.2 & "for information drawings",
 - □ technical requirements: to provide only interior communication distribution system to administration buildings only (AD 6 & A3)
 - □ for information drawings: interior communication provided in all other building types for Barracks B1, Barracks B8, Warehouse S1, Arms storage S3, Vehicle maintenance Bldg VM5 and POL storage VM5

Please advise which one to follow the Technical requirements or "for information drawings"

Response: Provide per FIO drawings, as directed by amendment #4.

48. The manufacturer of the existing switchgear in the power plant has advised that the existing lineup has maxed out on capacity; this lineup can not be expanded to accommodate the addition of the 2 new generators required for this solicitation. Please confirm that a new switchgear lineup to serve the new generators required for the additional loads is acceptable."

Response: Bid as required by contract. Per as-built information, switchgear is able to be extended.

(End of Summary of Changes)